



**OUTLET STRUCTURE**  
NTS

**NOTES:**

1. ALL FITTINGS TO BE RUBBER GASKETED.
2. ALL PVC RISERS AND FITTINGS INSTALLED ABOVE GRADE SHALL HAVE PROTECTIVE ULTRAVIOLET COATING, OPAQUE LATEX WATER BASED PAINT OR APPROVED EQUAL.
3. OUTLET RIM 3 INCH MINIMUM BELOW ADJACENT PAVEMENT OF SIDEWALK.

*Gary M. Schimek*

APPROVED BY: GARY M. SCHIMEK  
NATURAL RESOURCES/STORMWATER ENGINEERING MANAGER

REVISION DATE: MARCH 01, 2017



STANDARD DETAILS

**BIORETENTION OUTLET  
STRUCTURE**

FILE NAME: SD667.DWG

DETAIL NUMBER: 667